

VERIFICATION STATEMENT
FOR BATTERY

Statement No:
N141N1BH-1

Valid for products not subject to DNV GL classification requirements.

Particulars of Product

Product Name:	Recombination system
Type designation:	grid aquagen pro and grid aquagen pro max
Application/context:	VLA Recombination
ID/Serial/Tag no:	N.A.
The product is intended for:	STOCK
Requirements are based on:	Customer Specification - Hoppecke Standard

Deviations and limitations, if any, are stated on page 2 onwards.

Particulars of Vendor and Purchaser

Vendor:	Hoppecke Batterie Systeme GmbH
Vendor reference:	0010/ 045/ 4500827412
Purchaser:	
Purchaser reference:	

Issued at **Essen** on **2019-04-02**



for **DNV GL**

This document has been digitally signed and will therefore not have handwritten signatures

Hoppe, Christian
Surveyor



Verification extent and result

Verification extent:

witnessed:

1. efficiency of the Recombination system
2. backfire inhibition of the Recombination system
3. overload safety of the Recombination system

Verification result/comments:

Test were according to the specification passed.